

Public Water Supply District No. 3

of Franklin County Missouri

P.O. Box 160 • 150 Old Highway 100 • Villa Ridge, MO 63089
Phone: 636-742-5200 • Fax: 636-742-0224 • www.franklincountywater.com

July 25, 2022


RE: Franklin County PWSD 3
Notice of Violation – Public Notice Required

A Notice of Violation (NOV) was issued to Franklin County PWSD 3 by Missouri Department of Natural Resources on June 28, 2022. The Water District is required to collect nine (9) Bac-T samples per month. During the month of May, only eight (8) samples were collected. Although, all eight (8) samples passed, the one (1) sample missed by staff is the reason for the violation. The District's sampling procedures have been modified to include that future sampling will be reviewed by the Superintendent to prevent missed samples and violations.


Attached with this notice are the sample results from May 2022 as well as the Notice of Violation received from Missouri DNR.

If you have any questions or concerns regarding this notice, please contact our office at (636) 742-5200.

Sincerely,



Terry McDaniel
Local Manager
Franklin County PWSD #3




Missouri Department of Natural Resources
Water Protection Program - Public Drinking Water Branch

**Revised Total Coliform Rule
Notice of Violation-Public Notice Required**

Date of Report: June 28, 2022
PWS Name: FRANKLIN COUNTY PWSD 3

PWS ID: MO6024213
County: Franklin

ANGIE MILLER
150 OLD HWY 100
PO BOX 160
VILLA RIDGE, MO 63089



Please notify us of any name or address changes

The following is a summary of the bacteriological analysis of water samples submitted for the May 2022 monitoring period.

Sample Type	Number Required	Number Taken
Routine	9 per MN	Eight

Violation Type:


MONITORING, ROUTINE, MINOR (RTCR)

This is a violation of 10 CSR 60-4.022(3). The public water system (PWS) failed to collect all required routine drinking water samples from the distribution system for the designated compliance period.

Required Actions:

1. Collect the required number of routine samples before the end of each monitoring period. If you need additional sample bottles and use the Missouri Department of Health and Senior Services - State Health Laboratory for analyses, please either call 573-751-1077 or visit <https://dnr.mo.gov/water/business-industry-other-entities/technical-assistance-guidance/public-drinking-water-systems/request-additional-sampling-bottles>. If you use an independent laboratory, contact and request an adequate number of sampling kits from them for sampling.
2. The enclosures give instructions on how to perform public notice and a copy of the public notice itself to distribute, post and provide to any media.
3. Fill in the appropriate information requested on the certification page and sign where indicated.
4. Make copies of the certification and public notice (as seen by the public) for your files.
5. Send the completed certification and a copy of the public notice (as seen by the public) back to the Department's Water Protection Program, Public Drinking Water Branch at the address given.

For assistance, contact the Department's St Louis Regional Office at 314-416-2960 or the Water Protection Program, Public Drinking Water Branch at 573-526-6925.



MISSOURI
DEPARTMENT OF
NATURAL RESOURCES

Public Drinking Water Branch
P.O. Box 176
Jefferson City, MO 65102
(573)526-0135

RECEIVED
MAY 19 2022
BY: _____

Public Water System Bacteriological Report

PWS Name : FRANKLIN COUNTY PWS D 3
Mail to : TERRY MC DANIEL
150 OLD HWY 100
PO BOX 160
VILLA RIDGE, MO 63089

PWS ID : MO6024213
County : FRANKLIN
Please notify us of any
name and address changes

Date Collected :	Collector :	Sample Type :
05/10/2022	GOFORTH,ETHAN	Routine
Lab Sample ID :	Location Name:	Location ID:
OE670080	LOT #78 GOLDEN OAKS	18
Lab Results :		
A		
Coliform absent. Sample considered safe.		

Date Collected :	Collector :	Sample Type :
05/10/2022	GOFORTH,ETHAN	Routine
Lab Sample ID :	Location Name:	Location ID:
OE670078	76 ARBOR DRIVE - RED	09
Lab Results :		
A		
Coliform absent. Sample considered safe.		

Date Collected :	Collector :	Sample Type :
05/10/2022	GOFORTH,ETHAN	Routine
Lab Sample ID :	Location Name:	Location ID:
OE670079	HIGHWAY M - CAR WASH	10
Lab Results :		
A		
Coliform absent. Sample considered safe.		


Date Collected :	Collector :	Sample Type :
05/10/2022	GOFORTH,ETHAN	Routine
Lab Sample ID :	Location Name:	Location ID:
OE670081	564 RIDGEFIELD SUBDI	05
Lab Results :		
A		
Coliform absent. Sample considered safe.		

These sample test results were analyzed by the Missouri State Public Health Laboratory.

Note to Public Water Systems:

Routine samples must be taken from the distribution system. Routine samples collected at the well will be invalidated, possibly resulting in your system receiving a monitoring violation for failure to collect enough valid routine samples.

Friday, May 13, 2022



MISSOURI
DEPARTMENT OF
NATURAL RESOURCES

Public Drinking Water Branch
P.O. Box 176
Jefferson City, MO 65102
(573)526-0135

Public Water System Bacteriological Report

PWS Name : FRANKLIN COUNTY PWS D 3
Mail to : TERRY MC DANIEL
150 OLD HWY 100
PO BOX 160
VILLA RIDGE, MO 63089

PWS ID : MO6024213
County : FRANKLIN

Please notify us of any
name and address changes


Date Collected : 05/23/2022
Collector : HARMAN,MARTIN
Sample Type : Routine
Lab Sample ID : OE677520
Location Name: 1140 LAKEWOOD DR
Location ID: 20
Lab Results : A
Coliform absent. Sample considered safe.

Date Collected : 05/23/2022
Collector : HARMAN,MARTIN
Sample Type : Routine
Lab Sample ID : OE677517
Location Name: 76 ARBOR DRIVE - RED
Location ID: 09
Lab Results : A
Coliform absent. Sample considered safe.

Date Collected : 05/23/2022
Collector : HARMAN,MARTIN
Sample Type : Routine
Lab Sample ID : OE677519
Location Name: HOGAN ROAD - WOODLAW
Location ID: 13
Lab Results : A
Coliform absent. Sample considered safe.

Date Collected : 05/23/2022
Collector : HARMAN,MARTIN
Sample Type : Routine
Lab Sample ID : OE677518
Location Name: HIGHWAY M - CAR WASH
Location ID: 10
Lab Results : A
Coliform absent. Sample considered safe.

These sample test results were analyzed by the Missouri State Public Health Laboratory.



Note to Public Water Systems:
Routine samples must be taken from the distribution system. Routine samples collected at the well will be invalidated, possibly resulting in your system receiving a monitoring violation for failure to collect enough valid routine samples.

Thursday, May 26, 2022